



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on January 5, 2015.

**Krohne Altometer
Kerkeplaat 12
Dordrecht
3313 LC
The Netherlands
31 786306300**

Facility: Dordrecht, The Netherlands

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Water Meters [1]			
Optiflux 2000 F + IFC 010 W [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 010 W [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2000 F + IFC 050 W [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 050 W [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2000 F + IFC 100 W [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 100 W [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 F [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 F [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 R [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 R [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 W [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2000 F + IFC 300 W [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2010 C [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2010 C [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2050 C [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2050 C [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2100 C [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2100 C [3] [G]	[5]	CLD 23	MLTPL
Optiflux 2300 C [2] [G]	[4]	CLD 23	MLTPL
Optiflux 2300 C [3] [G]	[5]	CLD 23	MLTPL
Waterflux 3000 F + IFC 070 F* [7] [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 100 W [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 300 F [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 300 R [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 300 W [G]	[6]	CLD 23	MLTPL
Waterflux 3070 C* [7] [G]	[6]	CLD 23	MLTPL
Waterflux 3100 C [G]	[6]	CLD 23	MLTPL
Waterflux 3300 C [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 050 W [G]	[6]	CLD 23	MLTPL
Waterflux 3000 F + IFC 070 F [7] [G]	[6]	CLD 23	MLTPL
(IP68)*			

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.



Waterflux 3070 C (IP68)* [7] [G]	[6]	CLD 23	MLTPL
Waterflux 3050 C [G]	[6]	CLD 23	MLTPL

- [1] Only products bearing the NSF Mark are Certified.
- [2] Certified product contains Hastelloy C-22, Hastelloy C-4, or Stainless Steel 1.4571 electrodes and a hard rubber liner.
- [3] Certified product contains Hastelloy C-22, Hastelloy C-4, or Stainless Steel 1.4571 electrodes and a polypropylene liner.
- [4] DN25 - DN3000/1" - 120"
- [5] DN25 - DN150/1" - 6"
- [6] DN25 - DN 600/1" - 24"
- [7] * Option PT-Sensor possible
- [G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.